

Diesel generating set

AGLC45P

400V/50Hz Main power/Cummins 4BTA3.9-G2





ISO14001:2015

ISO9001:2015

OHSAS 18001:2007

Product features

// Operative norm:

- ISO 8528:AC generator set driven by reciprocating internal combustion engine
- IEC 60034-1:Basic technical requirements for rotating motors
- YD/T 502: Communication diesel generator set
- GB/T 20136-2006 General test method for internal combustion engine power stations

// Merit:

- ♦ Integrated building block structure design, small volume, compact structure, sophisticated technology;
- ♦ Few parts, light weight, low failure rate and low maintenance cost;
- ♦ Supercharging and supercharging intercooling technology as the leading products, strong power;
- ♦ High-performance damping system and rigid base, small vibration;
- ♦ Efficient fuel supply system and air intake system, fuel atomization and air mixing more fully, more complete combustion, lower emissions;
- ♦ Standardized design, comprehensive and intelligent products, parts and components have strong versatility, easy installation and easy maintenance;
- ♦ maintenance-free battery, with fast start performance;



Technical parameters of the unit

// Generator set

Generator model:	AGLC45P	Main power(kW):	<u>45</u>
Standby power(kW):	50	unit capacity(kVA):	56 . 3
Rated speed(rpm):	1500	Rated frequency(Hz):	50
voltage(V):	400	rated current(A):	81. 2
Power factor $(\cos \phi)$:	0.8(lag)	Wiring mode:	3 phase 4 wire
Generator weight (kg)	1015	Minimum smoke pipe diameter	(mm) 1× φ 64
Air intake(m³/min):	129	Air exhaust (m³/min):	126. 1
Generator size (mm): 230	0*1050*1300	Recommended base size(mm):	2400L×1200W

Unit performance index (G2)

Paramet	er	unit	Oerformance index
Frequency drop		%	≤5
Steady state frequenc	ey band	%	≤1.5
Relative frequency se	tting drop range	%	≥ 3. 5
Relative frequency se	tting rise range	%	≥ 2. 5
Transient frequency deviation	100% sudden power reduction	%	≤ +12
deviation	Surge power		≪ −10
Frequency recovery ti	me	S	€5
Relative frequency to	olerance band	%	2
Steady-state voltage deviation		%	$\leq \pm 2.5$
Voltage unbalance deg	gree	%	1
Transient voltage	100% sudden power reduction	%	≤ +25
deviation	Surge power		≤-20
Voltage recovery time		S	≤ 6
Voltage modulation		%	0.3
Relative voltage setting range		%	≤ ±5
Voltage setting rate of change		%/s	0.2~1
Telephone harmonic factor		%	<2
Telephone influence factor			<50



Engine technical parameters

// Engine

Manufacturer: Cummins
Model: 4BTA3.9-G2
Engine structure: four-stroke
Number: 4/L
Displacement:L 3.9
Cylinder diameter:mm 102
Stroke:mm 120
Compression ratio: 17.3:1
Speed:rpm 1500
Primary/standby power :: kW 50/55
Speed regulation mode:: E
Cooling method: closed water cooling
Dry weight (engine only): kg 350
// Start the system
Starting rated power:kW 6
Starting rated voltage:V DC24
// Fuel system
Fuel injection form: high pressure common
rail

// Fuel consumption

Engine output	L/h	g/kwh
100%	12.9	213
75%	10.0	219
50%	7.0	230
25%	4. 2	277

// Intake system

Maximum allowable intake resistanc	е
(clean filter element) : kPa 3.	7
Intake air flow: m³/min 2.94	ļ
// Lubrication system	
Total lubrication system capacity: L 10.	9

// Cooling system

Engine	coolant	volume:	L 2	2
Caalan	t flow:	I /min	0	c
cooran	t llow:	L/M1N	9	Ö

 $\underline{\text{Maximum allowable oil temperature}}: \underline{^{\circ}C121}$

// Exhaust system

Maximum exhaust back pressure:	kPa 10
Exhaust flow: kg/min	7.5
Exhaust temperature:℃	526

Technical parameters of generator


//Dynamo


*50Hz, AC400V, $\cos \Phi = 0.8$

MODEL	Rated power(k W)	Standby power(kW	Mechanic al efficien	Insulat ion	Class of protect	Weight(
LEROYSOMER: TAL-A42H	45	46. 4	86. 3	Н/Н	IP21	254



Size and weight





* The above figure is for reference only, the actual size and weight are subject to the final design drawing.

Mode1	Engine model	size (L×W×H) (mm)	Dry weight (kg)	Wet weight (kg)
AGLC45P	4BTA3. 9-G2	2300*1050*1300	985	1015

Special instructions

- // Main power (PRP) is the maximum power that the unit can run continuously with variable load under standard environment (atmospheric pressure, relative humidity, ambient temperature), and the overload of 10% is allowed to run for 1h every 12h.
- // Working conditions and power correction:

Altitude: $\leq 1500 \text{m}$ (> 1500m), need to do power correction; Power reduction by 10% per 1000m increase)

Ambient temperature: 40° C (when > 40° C, power correction is required)

Relative humidity: ≤60%

When the field use conditions of the diesel generator set do not meet the above conditions, the output power of the unit should be corrected, and the final correction coefficient, please refer to the detailed technical data of the corresponding engine and generator.

SHANGHAI AGRIPOWER INTIL CO., LTD Bldg 38th, No. 900 Haili Rd,

Jinshan District, Shanghai 201508. China T: +86 21 67290268 F: +86 21 67290269

Web: www.china-agripower.com